

CERTIFICATE OF COMPLIANCE

March 2026

Alspec Bushfire Compliant Product Range

The following window & door products supplied by Alspec have been tested by an independent testing authority to AS1530.8.1 (BAL40) achieving a no failure result. The following products tested for compliance are below:

Test Report Number: FSZ1662A¹

McArthur Top Hung Window

ProTilt Awning/Casement Window

Swan/Swan Evo Hinge Door

ASW44 Top Hung Awning Window

ASW44 Awning/Casement Window

ViewMax Sliding Window

AS85 Awning Casement Window

Hunter Evo Fixed Lite Frame

Hawkesbury Bi-Fold

Test Report Number: FE2548¹

Invisi-Gard Screening

Test Report Number: FRT230003⁶

McArthur EVO Fixed(SG)

Test Report Number: FRT210419¹

AirflowPlus Aero Louvre

Test Report Number: FRT210422⁵

ThermAFrame Sliding Door

Test Report Number: FRT230004⁷

Altitude Sliding Door

Test Report Number: FRT180019²

ProGlide High Performance Sliding Door

Test Report Number: FRT180020³

Hawkesbury Top Hung Sliding Door

Test Report Number: FRT180018¹

ThermAFrame Awning Window

ThermAFrame Casement Window

ThermAFrame Centre Pocket Fixed Lite

ThermAFrame Flushed Glazed Fixed Lite

ProVista Sashless Double Hung

Test Report Number: FRT210420⁴

ecoFRAMEplus Fixed

Test Report Number: FRT230001¹

AirflowPlus Breezway Louvre/Fixed(SG/DG)

Evo Plus Double Hung Window

Test Report Number: 260220¹

Carinya Comfort Hinged Door

Test Report Number: FRT252048¹

Carinya Comfort Sliding Window

Test Report Number: FRT252050⁵

Carinya Comfort Sliding Door

Test Report Number: FRT252048¹

Carinya Comfort Fixed Panel

Carinya Comfort Awning Window

Carinya Comfort Casement Window

Test Report Number: FRT252055⁶

Hunter Evo (SG101, SG150, DG101 and DG150)

NOTE:

The requirements under Australian AS3959-2018 standard for screening of openable parts of "windows" shall still apply to tested systems. Clause 3.8. Recommended material is stainless steel wire mesh.

Minimum 6mm toughened glass required in all products.

1. Maximum glass area of 2.4m² per pane.
2. Maximum glass area of 4.56m² per pane (Minimum 8mm toughened).
3. Maximum glass area of 4.31 m² per pane (Minimum 8mm toughened).
4. Maximum glass area of 6.25m² per pane (6/12/6 toughened).
5. Maximum glass area of 4.42m² per pane (6/16/6 toughened).
6. Maximum glass area of 6.28m² per pane.
7. Maximum glass area of 3.48m² per pane (6/8/4 toughened).

All previous test reports prior to the revised AS3959-2018 Australian Standard are applicable. This is a test summary.

For specific detailed information or test report contact Alspec.

